

4.3.1.3 Natural Gas Operated Appliances and Hookups

Natural Gas Appliance must be CSA approved and will require a gas permit (applied for by CS Trades Dept.) and inspected. The maximum number of appliances that may be operated per hall is limited to 10 (subject to not exceeding the btu calculation available from the Trades Superintendent). In addition a 10lb 2ABC fire extinguisher must be provided by the vendor prior to any operation of the appliances. These extinguishers must be fully serviceable, tagged showing who and when it was last professionally serviced, and should not be the domestic variety easily identified by the plastic head.

Under no circumstances are combustible materials are to be stored behind the appliance units.

- It is recommended that the vendor communicates the potential hazard from the operations of the appliances to workers in adjacent booths.